

**CLARK COUNTY****RFP #829****SELECT ENGINEERING SERVICES for PAVEMENT IMPROVEMENTS of
ST. JOHNS ROAD (NE 68th STREET to NE 78th STREET)****QUESTIONS and ANSWERS****UPDATED: JUNE 3, 2022**

	QUESTION	ANSWER
1.	Section B1 Required Services indicates the Consultant will provide: "Traffic Engineering - Technical guidance and assistance (Traffic control plans, detours, etc)" (item #2 under Engineering Services). Does this work also include design of ADA pushbutton retrofits?	The County will design the ADA pushbutton retrofits and provide the plans to the consultant to include in final plan set.
2.	Section B2 County Performed Work indicates that the County will provide: "Coordinating all environmental permitting submittals and correspondence with federal, state, and local agencies." (item #9) Does County Performed Work also include preparing permits for submittal?	Yes, The County will be preparing environmental permits for submittal
3.	Which signalized intersections are scoped to receive signal modifications?	Currently, there are no intersections receiving signal modifications.
4.	Which intersections are scoped to receive pedestrian ramp improvements?	Intersections on St Johns Rd at NE 68th St, NE 37th Ave, NE 40th Ave, & NE 43rd Ave
5.	Will the entire roadway be re-striped? Is the County wanting to optimize the striping layout or generally replace existing?	The entire roadway will be re-striped generally replacing the existing layout
6.	Are there any asbuilts or information on the existing concrete roadway construction/section?	Yes, there are as-built plans of the concrete roadway available.
7.	What ROW acquisition is expected?	ROW acquisition, if needed, will be provided by the county.
8.	Is this "UDBE" or "DBE?"	UDBE
9.	Will Clark County do the real property acquisition and environmental permitting?	Yes, Clark County is doing the real property acquisition and environmental permitting.
10.	What does environmental "coordination" mean specifically?	Services that may be needed: Provide environmental documentation & permitting support for the County project manager

		and permit coordinator, attend team meetings on an as needed basis, develop Stormwater Pollution Prevention Plan, develop mitigation plans as necessary including the development of bid items, ensure NEPA and SEPA procedures are followed during all phases of the project
11.	Will Clark County provide survey for ADA ramps as well?	Yes, Clark County will provide the survey for the ADA ramps needed.
12.	Will the concrete roadway be diamond ground after the panels are replaced?	Concrete panels shall be finished in accordance with WSDOT 2022 Standard Specifications section 5-01.3